## **Engine Data**

Emission Unit Number	Emission Unit Description	Is this an emergency engine?	Construction Date	Engine Model Year	Brake Horsepower (bhp)
EU12	Diesel Generator	No	1994	1993	2304
					-
		open o		,7U= I=	-
					* m8
				S 5.71	
					8

Existing units: Initial notifications are required to be submitted by August 31, 2010 for the following:

Area sources:

Non-emergency engines > 300 bhp, installed before June 12, 2006

Major sources:

Non-emergency engines > 500 bhp, installed before December 19, 2002, and

Non-emergency engines > 100 and  $\le 500$  bhp, installed before June 12, 2006

New units: Initial notifications are required to be submitted within 120 days of startup for the following:

Major sources:

All engines > 500 bhp installed on or after December 19, 2002

## Signature

Responsible Official Certification						
I certify the truth, accuracy, and completeness of this notification.						
Responsible Official Signature	Date					
Dun Van hombr	August 31,2010					
	uracy, and completeness of this notific					

Submit this notification to the following agencies:

- Director, Air and Waste Management Division, U.S. Environmental Protection Agency, 901 N. 5th Street, Kansas City, KS 66101
- NESHAP Coordinator, Iowa Department of Natural Resources, 7900 Hickman, Suite 1; Windsor Heights, IA, 50324
- If the facility is located in either Linn County or Polk County, this notification shall <u>also</u> be submitted to the appropriate county office:

**Polk County Public Works** – Air Quality Division 5885 NE 14<sup>th</sup> Street; Des Moines, IA 50313

**Linn County Public Health** - Air Quality Division 501 13<sup>th</sup> Street NW; Cedar Rapids, IA 52405